



Confirmation

Confirmation-No. IS-AN5-MUC-2512-5010884972-001

Haelok AG
Rütistrasse 26
8952 Schlieren
Schweiz

We hereby confirm leak testing and approval of the above company's HAELOK® system. Details can be found in the corresponding investigation report with the order no. 3590829.

Description of the compression coupling system:
HAELOK®-System

HAELOK® compression coupling system consisting of:

- Steel 1.0570 galvanized couplings, named CC
- Stainless steel 1.4404 couplings, named XX

Requirements:

- Representation of the leak according to EN 1779:1999
- Couplings installed with the HAELOK® Presstool


The attestation is based on, among other things:

- Visual examinations
- pressure test
- Leakage measurement with helium (EN 1779:1999)

This attestation is valid until December 2028.

Munich, 15 December 2025

TÜV SÜD Industrie Service GmbH
Institute for Plastics


i. A. Schweizer

